

**Tender for**

---

**Supply, Erection, Installation, Testing and Commissioning of 11KV OH HT Conductor Line and UG HT  
Armoured Cable with DGMS approval**

**At**

**GMDC Ltd.,**

**Lakhpat Punrajpur Lignite Project,**

**PO: Ghaduli, Ta: Lakhpat, Dist: Kutch,**

**Gujarat – C370627**

**INDIA**

---

**Tender No.: GMDC/TECH-1/LP/ELE/01/2026-27**

**Corrigendum Document – 1**

**Gujarat Mineral Development Corporation**

**July 2026**

**Point A of Clause 11.12, i.e. Technical Specifications stand amended as below.**

<b>Event Description</b>	<b>Tender Clause</b>	<b>Amended Clause</b>
Specification of Earth Wire	All the erected 11 KV poles and DP structures shall be protected by connected single run stranded <b>Aluminum conductor</b> as earth wire throughout the line length and to be connected with providing separate pipe earthing earth pit at every four to five pole spans in addition to separate pole earthing through 8 SWGGI wire.	All the erected 11 KV poles and DP structures shall be protected by connected single run stranded <b>GI</b> earth wire throughout the line length and to be connected with providing separate pipe earthing earth pit at every four to five pole spans in addition to separate pole earthing through 8 SWGGI wire.